Tecnosens S.p.A.
Via Vergnano,16 25125
Brescia (BS) Italia

Tel: (+39) 030 3534144
Fax: (+39) 030 3530815
info@tecnosens.it
PEC: tecnosens@legalmail.it



GYcAT4

Product code: GYcAT4
Manufacturer: Santest

Analogue output, replacement for GYLT, GYLS probe.

Power Supply	+24 (±2)VDC (100mA)
Sampling frequency	Std 1kHz
IP Index	IP67
Non-linearity	≤± 0.05%FS TYP
Max pressure	35MPa (rod type)
Repeatability	≤0.01%FS
Resolution	≤0.01%FS
Shock	50G (2msec)
Working temperature	From -20°C to +80°C
Temp. drift	≤±40ppmFS/°C
Output type	0-10V o 10V-0 / 4-20mA o 20-4mA
Vibration	6G

© Tecnosens S.p.A. 2026